

# General Environmental Incident Summary

**Incident:** 1955      **Date/Time Notice:** 6/25/2013      1455      **DEM Incident No:**  
**Responsible Party:** Minnesota Power  
**Date Incident:** 6/24/2013      **Time Incident:** 0800      **Duration:** 15 minutes  
**County:** Oliver      **Twp:** 142      **Rng:** 83      **Sec:** 33      **Qtr:**  
**Lat:** 47.07537      **Long:** -101.20390      **Method:** Derived from TRS  
**Location Description:** 3325 24th St SW, Center, ND. A substation.

**Submitted By:** William Fraundorf      **Affiliation:**  
**Address:**  
**City:**      **State:**      **Zip:**

**Received By:**

**Contact Person:** Tyler Hardy  
2375 33rd Ave SW  
Center, ND

**Distance Nearest Occupied Building:** 500 Feet

**Type of Incident:** Transformer oil spill

**Description of Released Contaminant:** No-PCB Mineral Oil (transformer oil)

**Volume Spilled:** 1.00 gallons      **Ag Related:** No

**EPA Extremely Hazardous Substance:** No      **Reported to NRC:** No

**Cause of Incident:**

Damaged unit weeped oil.

**Risk Evaluation:**

No associated human health risks.

**# of Fatalities:** 0      **# of Injuries:** 0      **Affected Medium:** 09 - other

**Potential Environmental Impacts:**

No environmental impact anticipated.

**Action Taken or Planned:**

The oil was contained in the crushed rock substation surface. The oily crushed rock was shoveled up and drummed (1 drum ). The damaged unit will be replaced.

**Wastes Disposal Location:** With Clean Harbors, Inc.

**Agencies Involved:**

## ***Updates***

---

***Date:*** 6/25/2013

***Status:*** Assigned to WM

***Staff:*** Roberts, Kris

***Updated Volume:***

***Notes:***

1 gallon spill of non-PCB transformer oil was cleaned up by Minnesota Power personnel. Referred to Waste Management Div for any necessary follow-up.